

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1090165

Product: Conductor for lightning and earthing

Type: wire 7, 8, 10 mm; string 30x4 mm, 20x3 mm; cable 50 mm²
variants: hot-dip galvanizing steel, copper, stainless steel,
AlMgSi, hot-dip galvanizing steel with PVC insulation

Rating: wire diameter 7, 8, 10 mm; string 30x4 mm, 20x3 mm; cable cross section 50 mm²

Ordering firm: TREMIS s.r.o.
Lukavec čp. 28, 410 02 Lovosice, Czech Republic

Manufacturer: TREMIS s.r.o.
Lukavec čp. 28, 410 02 Lovosice, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 900340-01/01 of: 02.03.2009

A sample of the product was found to be in conformity with:
ČSN EN 62305-3:06+1:07; ČSN EN 50164-2:03+A1:07 cl 5.2, 5.2.1, 5.2.2; ČSN 33 2000-5-54:07 ed.2

The validity of the certificate is limited to: 28.2.2012

2.3.2009

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp



900340-01