

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1200062

**Product:** Lightning conductors and grounding system's parts - conductor fasteners and accessories

**Type:** PV, DOU, DUD, DJD (see Enclosure)

**Rating:** conductor diameter 8 - 10 mm, air terminator rod diameter 18 mm

**Ordering firm:** TREMIS s.r.o.  
č.p.28, 410 02 Lukavec, Czech Republic

**Manufacturer:** TREMIS s.r.o.  
č.p.28, 410 02 Lukavec, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 020252-01/01 of: 07.02.2020

**A sample of the product was found to be in conformity with:**  
ČSN EN 62561-4 ed.2:18

**Other data:**

**The validity of the certificate is limited to:** 20.02.2023

21.02.2020

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



020252-01