

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1170651

Product: Lightning conductors and grounding system's parts- clamps

Type: see enclosure

Rating: ring wires Ø 8 - 10 mm, strip wires 30x 4 mm

Ordering firm: TREMIS s.r.o.
Lukavec 28, 410 02 Lukavec, Czech Republic

Manufacturer: TREMIS s.r.o.
Lukavec 28, 410 02 Lukavec, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 702846-01/01 of: 16.08.2017

A sample of the product was found to be in conformity with:
ČSN EN 62561-1:12 cl. 5.2, 5.7, 5.10, 6.2.2, 6.4, 6.5

Other data:

The validity of the certificate is limited to: 31.08.2020

05.09.2017

Prague


Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



702846-01