

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1200423

Product: Lightning conductors and grounding system's parts- clamps

Type: see Enclosure

Rating: ring wires \varnothing 8 - 10 mm, strip wires 30x4 mm

Ordering firm: TREMIS s.r.o.
č.p.28, 410 02 Lukavec, Czech Republic

Manufacturer: TREMIS s.r.o.
č.p.28, 410 02 Lukavec, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 021914-01/01 of: 25.08.2020

A sample of the product was found to be in conformity with:
ČSN EN 62561-1 ed.2:17 cl. 5.2, 5.8, 5.11, 6.3, 6.4, 6.6

Other data:

The validity of the certificate is limited to: 27.08.2023

28.08.2020

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



021914-01