

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lísem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1210024

Product: Conductor for lightning and earthing

Type: Wire 8, Wire 10, Wire 10/13 PVC, Cable 50, String 20x3, String 30x4, wire 7 Cu T/2, wire 8 Cu T/2, wire 8 Cu T/4, wire 8 N, wire 10 N V4A, string 30x3,5 N, string 30x3,5 N V4A, wire 8 AlMgSi T/2, wire 8 AlMgSi T/4, wire 8 AlMgSi+PVC, spindle M10, spindle M10 N V4A

Rating: Ø wire 7,8,10 mm; string 20x3, 30x4, 30x3,5 mm; cable cross section 50 mm², spindle M10 Ø 10 mm, see Enclosure

Ordering firm: TREMIS s.r.o.
č.p.28, 410 02 Lukavec, Czech Republic

Manufacturer: TREMIS s.r.o.
č.p.28, 410 02 Lukavec, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 022915-01/01 of: 21.01.2021

A sample of the product was found to be in conformity with:
ČSN EN 62561-2 ed.2:18 cl. 4.3, 4.4, 5.2.2, 5.2.3, 5.2.4, 5.2.5, 5.2.6

Other data:

The validity of the certificate is limited to: 03.02.2024

04.02.2021

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



022915-01