

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 182 00 Praha 8, Troja

CERTIFICATE

No.: 1230494

Product: Lightning conductors and grounding system's parts- air-termination rods, insertion rods, earthing rods and plates

Type: see Annex

Rating: air-termination - \varnothing 18, earthing rod - \varnothing 25, 50x50x3, 2000x250, 1000x500, \varnothing 18, \varnothing 20

Ordering firm: TREMIS s.r.o.
č.p.28, 410 02 Lukavec, Czech Republic

Manufacturer: TREMIS s.r.o.
č.p.28, 410 02 Lukavec, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 232426-01/01 of: 30.10.2023

A sample of the product was found to be in conformity with:
ČSN EN IEC 62561-2 ed. 2:18 No. 4.3, 4.5, 5.2.5, 5.2.6

Other data:

The validity of the certificate is limited to: 01.11.2026

02.11.2023 'Corrigendum 13.12.2023

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



232426-01